

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

471105-13924

Dated: 21.07.2023

It is certified that an inspection team headed by MEDICAL HEALTH AND FAMILY WELFARE DEPT
(Name of Officers with designation) from DR. GOPILAL (A.C.M.O) Amroha.
(Name of Department/ Office) inspected the ST. JOHN'S CONVENT SCHOOL PREMDDHAM GAJRAULA
(Name & Address of the school) on 20-07-2023 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One Year

Signature with Seal: A. C. M. O.
Distt. Amroha

Name : DR. GOPILAL

Designation : ACMO, Amroha.

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

To

St. John's Convent School
Premddham, Yak Bagri, Gajraula(Amroha)

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.


Manager

St. John's Convent School
Premddham, Yakbagri Gajraula,
(Amroha) (D.T.) U.P.-244235


Principal

St. John's Convent School
Premddham, Yakbagri Gajraula,
(Amroha) (D.T.) U.P.-244235



कार्यालय
अधिशाली अभियन्ता, खण्ड कार्यालय, उ०प्र० जल निगम (ग्रामीण),
अमरोहा

पत्रांक 1857 / केमिअल टोस्ट / 45 दिनांक 07/08/23

सेवा में,

Manager,
ST. JOHN'S CONVENT SCHOOL
Premdham, Yak Bagri, Gajraula,
Amroha

विषय:- पीने के पानी की गुणवत्ता जांच के संबंध में।

महोदय,

उपरोक्त विषयक आपके द्वारा दिनांक 07-08-2023 के संदर्भ में प्राप्त कराये गये पेयजल नमूने की जांच खण्डीय प्रयोगशाला में की गई। जांच रिपोर्ट संलग्न कर प्रेषित है।

संलग्नक उपरोक्तानुसार

भवदीय

(Shah203)
शाहरोज आरिफ
सहायक अभियन्ता
SWSM सहायक अभियन्ता

पृ०सं० एवं दिनांक उपरोक्तानुसार।

प्रतिलिपि:- अधिशाली अभियन्ता/जू०इं० (लैब) को सूचनार्थ हेतु प्रेषित।

(Shah203)
सहायक अभियन्ता

Manager
St. John's Convent School
Premdham, Yakbagri Gajraula,
(Amroha) (D.T.) U.P.-244235

Principal
Convent School
Yakbagri Gajraula,
U.P.-244235



कार्यालय अधिशासी अभियन्ता, खण्ड कार्यालय, उ०प्र० जल निगम(ग्रामीण), अमरोहा
प्रयोगशाला टैस्टिंग रिपोर्ट

क्र०सं०	नगर / मौहल्ले का नाम	स्थल का नाम / लोकेशन	श्रोत का नाम	रंग	गंध	गंदलापन	टी०डी० एस०	पी०एच०	रासायनिक परीक्षण (पी०पी०एम० में)					अन्य विवरण
									क्लोराईड	कुल क्षारीयता	सम्पूर्ण कठोरता	आयरन	नाइट्रेट	
						(NTU)	Limit 50-2000	Limit 6.5-8.5	Limit 250-1000	Limit 200-600	Limit 300-800	Limit 0 - 0.3	Limit 45	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
	गजरौला	ST. JOHN'S CONVENT SCHOOL Premdhan, Yak Bagri, Gajraula, Amroha	सबभरसेविल	रंगहीन	गंधहीन	0.25	254	7.10	60	240	260	-	-	संतोषजनक


Tested by lab Assistant

Approved by Chemist

CHEMIST
Water Testing Laboratory
U.S. Jai Jai Garam, Amroha

शाहरोज अहिर
सहायक अभियन्ता
SIA/SM


Manager
St. John's Convent School
Premdham, Yakbagri Gajraula,
U.P. U.P.-244235


Principal
St. John's Convent School
Premdham, Yakbagri Gajraula,
Amroha (D.T.) U.P.-244235